CONTROL OF HAZARDOUS ENERGY GROUP ROSTER

The lead authorized worker signature indicates that the lockout is complete and the system is safe for work.

Continuity of protection: The lead authorized worker must install lock and sign on before start of any work under this procedure, and must stay locked on until all work is complete and all authorized employees have removed their locks and signed off. If a group lockbox is used, the lead authorized employee must apply a group lockout master lock to the group lockbox. The group lockout master lock is applied before start of any work, and must remain installed until all work is complete and each authorized employee has removed his/her lock.

If necessary, lead authorized worker duties may be reassigned to another authorized employee. All employees performing work under this energy control procedure must be informed of the reassignment.

Energy Control Procedure ID:	**Building:**	**Task:**
Lead authorized employee(s) *(print name)*	**Lock Installed** *(signature and date)*	**Lock Removed** *(signature and date)*
Authorized employee(s) *(print name)*	**Lock Installed** *(signature and date)*	**Lock Removed** *(signature and date)*

Notes: