

CONTROL of HAZARDOUS ENERGY (LOCKOUT/TAGOUT) PROGRAM



Table of Contents

1.0	Purpose and Applicability.....	2
2.0	Scope.....	2
3.0	Responsibilities.....	2
4.0	Definitions.....	3
5.0	Control of Hazardous Energy (Lockout/Tagout) Principles.....	5
6.0	Procedures.....	6
7.0	Removal of Authorized Employee Locks and Tags When Off-site	10
8.0	Contractors.....	10
9.0	Control of Hazardous Energy (Lockout/Tagout) Periodic Inspections	11
10.0	Personnel Control of Hazardous Energy (Lockout/Tagout) Training	12
11.0	Recordkeeping	12
12.0	References.....	13
ATTACHMENT A – EQUIPMENT HAZARDOUS ENERGY CONTROL PROCEDURE		14
ATTACHMENT B – GROUP ROSTER		17
ATTACHMENT C– PERIODIC REVIEW FORM.....		18

1.0 Purpose and Applicability

- 1.1 It is the policy of the University of Pennsylvania in coordination with the Office of Environmental Health and Radiation Safety to provide the Penn community with a safe and healthful environment.

This program is presented to ensure that employees place machinery, equipment, or systems capable of causing injury by energizing, unexpected starting or releasing stored energy, into a safe condition and that the safe condition is maintained throughout the duration of the task.

- 1.2 This program applies to all University of Pennsylvania employees.

2.0 Scope

- 2.1 Effective hazardous energy control procedures will protect employees potentially exposed to unexpected energizing or release of stored energy that could cause injury during the servicing or maintenance of machines, equipment, or systems, as well as while working on or near exposed de-energized electrical conductors and parts of electrical equipment.
- 2.2 This program does not apply to work on cord and plug connected electrical equipment where exposure to the hazards of unexpected energization or startup of the equipment is controlled by unplugging of the equipment from the energy source and by the plug being under the exclusive control (within arm's reach and line of sight) of the employee performing the servicing or maintenance.

3.0 Responsibilities

- 3.1 **Environmental Health and Radiation Safety shall be responsible for:**
- 3.1.1 Development, auditing and updating of this program.
 - 3.1.2 Aiding end users with implementation of the program.
 - 3.1.3 Completing periodic audits and updating of control of hazardous energy procedures.
 - 3.1.4 Coordinating or providing required training.
- 3.2 **Supervisors shall be responsible for:**
- 3.2.1 Initiating and controlling this program.
 - 3.2.2 Ensuring that the proper procedures for isolating all energy sources have been implemented.
 - 3.2.3 Identifying personnel required to complete Penn's Control of Hazardous Energy (Lockout/Tagout) training.

3.3 **Authorized Employees shall be responsible for:**

- 3.3.1 Performing hazardous energy control in compliance with this program, related procedures and the training provided to them.
- 3.3.2 Notifying supervisors of the need for procedure updates.

4.0 Definitions

- 4.1 **Affected Employee** - An employee whose job requires operation or use a machine, equipment, or system on which servicing, or maintenance is being performed under lockout/tagout (LOTO), or whose job requires working in an area where such servicing or maintenance is being performed.
- 4.2 **Authorized Employee** - An employee who locks out or tags out machines, equipment, or systems to perform servicing or maintenance on that machine, equipment, or system. An affected employee becomes an authorized employee when that employee's duties include performing servicing or maintenance covered under this program.
- 4.3 **Authorized Locks and Tags** - Locks and tags that are used to ensure the safety of the authorized employees performing servicing and maintenance of machines, equipment, or systems. Servicing or maintenance may not begin until these devices are applied to the energy isolation device(s). These locks and tags shall not be used for any other purpose. The locks shall be singularly keyed, and the authorized employees shall retain the keys to individual locks. The keyed lock shall be red in color. The recommended lock is [Master Lock Model 410 Red](#). The print and format of tags shall be standardized and shall warn against hazardous conditions if the machine, equipment, or system is energized. The tag shall read "**Danger – Do Not Operate**" and shall have black lettering with a white background. The tag shall have an unlocking strength of at least 50 pounds. Locks and tags shall clearly identify the authorized employee applying the devices.
- 4.4 **Energy Isolating Device** - A mechanical device that physically prevents the transmission or release of energy, including but not limited to the following: a manually operated electrical circuit breaker, a disconnect switch, a manually operated switch by which the conductors of a circuit can be disconnected from all ungrounded supply conductors, and, in addition, no pole can be operated independently; a line valve; a block; and any similar device used to block or isolate energy. Push buttons, selector switches and other control circuit type devices are not energy isolating devices. For lockout/tagout purposes, isolating devices that provide visible indication of the device's position are desirable.
- 4.5 **Hazardous Energy** - Any electrical, mechanical, hydraulic, pneumatic, chemical, nuclear, thermal, gravity or other energy that could cause injury to personnel.
- 4.6 **Lead Authorized Employee** - The designated authorized employee who shall be responsible for lockout/tagout of each energy isolating device and providing a single location or device that

allows each member of the group to apply their individually controlled lock or tag in a group lockout/tagout task.

- 4.7 **Lockout Device** - A device that utilizes a positive means, such as a lock, that secures an energy isolating device in a position that prevents the energizing of a machine, equipment, or system. Other lockout devices include dead ends (blanks), bolted slip blinds, valve hand wheel covers, and chains/lock.
- 4.8 **Lockout Fixture** - An appliance that accommodates one or more locks to secure an energy isolating device.
- 4.9 **Lockout/Tagout (LOTO)** - The placement of a lock/tag on the energy isolating device in accordance with an established procedure, indicating that the energy isolating device shall not be operated until removal of the lock/tag in accordance with an established procedure. (The term “lockout/tagout” allows the use of a lockout device, a tagout device or a combination of both.)
- 4.10 **Safe Condition Check (Verification of De-Energizing)** - The inspection or test of a machine, equipment, or system performed by the Authorized Employee to ensure that the hazardous energy or materials are controlled to prevent injury or accident. **Note: This is an essential element of all hazardous energy control programs and procedures which ensures the safety of all potentially exposed personnel.**
- 4.11 **Servicing/Maintenance** - Workplace activities such as constructing, installing, setting up, adjusting, inspecting, modifying, and maintaining and/or servicing machines, equipment, or systems. These activities include lubrication, cleaning or unjamming of machines, equipment or systems and making adjustments or tool changes where the employee may be exposed to the unexpected energization or start-up of the machine, equipment, or system or release of hazardous energy.
- 4.12 **Supervisor** - One who has the responsibility of overseeing lockout/tagout activities.
- 4.13 **Tag** - A “Danger – Do Not Operate” tag, that can be securely fastened (with an unlocking strength of 50-pounds) to an energy isolating device to indicate that the energy isolating device and the machine, equipment, or system being controlled cannot be operated until the tag is removed. Tags are essentially warning devices affixed to energy isolating devices and do not provide the physical restraint of a lock.

5.0 Control of Hazardous Energy (Lockout/Tagout) Principles

This program establishes the requirements for the lockout/tagout of energy isolating devices.

- 5.1 It is mandatory that all University of Pennsylvania personnel comply with this Control of Hazardous Energy (Lockout/Tagout) Program and related procedures.
- 5.2 No individual shall attempt to start, energize, use, or operate machinery, equipment, or a system that has been locked and tagged out after the safe condition check has been completed.
- 5.3 No individual, other than the Authorized Employee who installed the lockout/tagout device and tag, shall attempt to remove them, except as noted in Section 7.
- 5.4 Lockout/tagout equipment shall be stored in the appropriate shops or local locations where it will be used. Some Authorized Employees may maintain position of personal locks.
- 5.5 The “Danger - Do Not Operate” tag signifies that there is an authorized employee working on a machine, equipment, or system, and it was installed by that task’s Authorized Employee prior to starting work and will be removed by that Authorized Employee when their work is completed.
- 5.6 The “Danger – Do Not Operate” tag is reserved for the exclusive use of the Authorized Employee identified on that tag. Tags must be legible and understandable by all authorized and affected employees whose work operations are, or may be, in the area to be affective. Tags and their means of attachment must be made of materials which will withstand the environmental conditions encountered in the workplace.
- 5.7 No person shall remove a lockout device or tag when an unsafe condition exists until they have corrected the condition, or another person has installed a lockout device or tag.
- 5.8 Affected Employees shall be notified by the University of Pennsylvania (Penn) or the Authorized Employee of the application and removal of lockout devices or tags. Notification shall be given before the controls are applied and after they are removed from the machine, equipment, or system.
- 5.9 A check valve cannot be used as an energy isolation device.
- 5.10 Whenever outside personnel (contractors, etc.) are to be engaged in activities covered by the scope and application of this program, Penn and the outside employer shall inform each other of their respective control of hazardous energy procedures. Penn shall ensure

that its employees understand and comply with the restrictions and prohibitions of the outside employer's energy control program.

- 5.11 When electrical system grounds need to be applied, they shall be the last devices applied and the first devices removed in the application of control of hazardous energy (lockout/tagout). Only qualified electrical personnel shall apply grounding devices.
- 5.12 All employees shall receive the appropriate level of training based upon their control of hazardous energy (lockout/tagout) duties (i.e., Authorized, Affected).
- 5.13 Any employee who observes any apparent violation of this program or related procedures shall immediately notify their supervisor.

6.0 Procedures

A specific written energy control procedure for all applicable machines, equipment or systems is developed and shall be followed before beginning any servicing or maintenance work.

6.1 Detailed Control of Hazardous Energy (Lockout/Tagout) Procedure

- 6.1.1 The Authorized Employee shall identify all potential sources of hazardous energy. The Authorized Employee shall develop a specific written energy control procedure for isolating the machine, equipment, or system if one does not already exist. The written procedure shall be documented on an equipment energy control procedure form. (Attachment A).
- 6.1.2 The Authorized Employee shall obtain the necessary lockout/tagout equipment from the appropriate supervisor or storage location.
- 6.1.3 The Authorized Employee shall place the machine, equipment, or system in a zero-energy state by performing a normal shut down and then following the equipment energy control procedure.
- 6.1.4 Locks and tags shall be installed on the energy isolation devices/fixtures in the proper order listed on the equipment energy control procedure form. After removing each key from the lock, the Authorized Employee will place the keys into the lockbox which is used to prevent them from being misplaced. The Authorized Employee shall then place their lock and tag on the lockbox and lock it with their personal key. The Authorized Employee shall keep their personal key. In addition, a designated supervisor may put their lock on the lockbox. This would only be completed to secure the lockbox if an employee left the jobsite and another employee took control of the job. The new employee would then be required to put their lock on the lockbox and proceed to follow

all of the required control of hazardous energy (lockout/tagout) procedures stated in this program.

- 6.1.5 When all energy isolation devices have been properly de-energized and locked/tagged out, the Authorized Employee shall perform the necessary safe condition check(s) to ensure that all hazardous energy has been dissipated and controlled. (Example: pushing local start buttons, throwing switches, etc.). The task can now begin.
- 6.1.6 When the task is complete, the Authorized Employee shall make sure that personnel are a safe distance from all machines, equipment, or systems before energizing.
- 6.1.7 Lockout/tagout devices removal. The Authorized Employees will remove their personal locks from the lockbox and then remove all locks and tags from all energy isolation devices. Upon completion, the Authorized Employees' locks shall be placed back into the lockbox. The machine, equipment, or system will be energized in the proper order noted on the control of hazardous energy (lockout/tagout) procedure. The machine, equipment, or system will then be put back into service as required.

6.2 **Application of Control:**

The written equipment energy control procedure must include the following steps for proper control and isolation of energy:

- 6.2.1 **Notify Affected Employees** - Affected Employees must be notified that work will be performed on the machine, equipment, or system.
- 6.2.2 **Preparation for Shutdown** - The Authorized Employees shall have knowledge of the type and magnitude of the energy, the hazards to be controlled, and the method or means to control the energy.
- 6.2.3 **Machine, Equipment, or System Shutdown** - The machine, equipment, or system shall be turned off or shut down using normal procedures to avoid any increased risk to the employee(s).
- 6.2.4 **Machine, Equipment, or System Isolation** - All energy isolating devices/fixtures needed to control the energy shall be physically located and operated in a manner to isolate the machine, equipment, or system from the hazardous energy source.
- 6.2.5 **Application of Lockout/Tagout Devices** - A lock and tag must be applied to each energy isolating device. Each person working on a machine, equipment, or system must apply a lock and tag. For example, if a qualified electrician is required to isolate the equipment but will not be the person performing the task,

the electrician will install a lock on the lockout device/fixture as well as the Authorized Employee(s) performing the task.

- 6.2.6 **Dissipate Energy** - After applying locks/tags to the energy isolation devices, all potentially hazardous stored or residual energy must be relieved, blocked, bled, restrained, or rendered safe.
- 6.2.7 **Verification of Isolation** - Prior to starting work on machines, equipment, or systems that have been locked and tagged, the Authorized Employee(s) shall, if possible, verify that all energy sources have been isolated by attempting to operate the machine, equipment, or system using local start buttons, switches, valves, etc., then returning them to the off/neutral position once the verification of isolation has been completed.
- 6.2.8 **Release from Lockout/Tagout Control** - Prior to restoring energy to the machine, equipment, or system, remove all tools, ensure all guards are installed and that Affected Employees are clear and informed that energy to the equipment will be restored. All locks/tags can then be removed, and the energy restored.

6.3 **Control of Hazardous Energy (Lock-Out/Tag-Out) Between Shifts:**

Employees working on a machine, equipment, or system must use their own provided lock and adhere to Penn's Control of Hazardous Energy (Lockout/Tagout) Program, but if an Authorized Employee's shift ends prior to completion of the work, they must follow the procedure below:

- 6.3.1 The lock and tag of the Authorized Employee that is leaving must remain on the equipment until the lock and tag of the incoming Authorized Employee is placed on the energy-isolating device.

6.4 **Exceptions to Written Control of Hazardous Energy (Lockout/Tagout) Procedures**

There are occasions where specific written control of hazardous energy (lockout/tagout) procedures are not required. They are not required when **ALL** the following elements exist:

- 6.4.1 The machine, equipment, or system has no potential for stored or residual energy or re-accumulation of stored energy after shutting down which could endanger employees.
- 6.4.2 The machine, equipment, or system has a single energy source that can be readily identified and isolated.
- 6.4.3 The isolation and locking out of the single energy source will completely deenergize and deactivate the machine, equipment, or system.

- 6.4.4 The machine, equipment or system is isolated from that energy source and locked out during servicing or maintenance.
- 6.4.5 A single lockout device will achieve a locked-out condition.
- 6.4.6 The lockout device is under the exclusive control of the Authorized Employee performing the servicing or maintenance.
- 6.4.7 The servicing or maintenance does not create hazards for other employees.
- 6.4.8 Penn, in utilizing this exception, has not experienced an incident or accident involving the unexpected activation or reenergizing of the machine, equipment, or system during servicing or maintenance.

6.5 Multiple Personnel Protection (Group Lockout/Tagout)

- 6.5.1 When multiple energy isolating devices protecting the affected work activity are secured by lockout/tagout but are not applied directly by each authorized individual, a designated individual shall be responsible for lockout/tagout of each energy isolating device and providing a single location or device that allows each member of the group to apply their individually-controlled lock or tag. This individual is designated as the Lead Authorized Employee.
- 6.5.2 The Lead Authorized Employee shall have all the duties as stated in Sections 6.1 & 6.2 and has the responsibility as the supervisor to ensure continuity of protection for all Authorized Employees and to coordinate affected trades. The Lead Authorized Employee shall ensure all locks and tags are properly installed on the energy isolating devices by visually checking all energy isolation points.
- 6.5.3 The Lead Authorized Employee shall use the Control of Hazardous Energy Group Roster (Attachment C) to list all other Authorized Employees on the group lockout with whom they are working.
- 6.5.4 Each Authorized Employee shall put their own lock on the lockbox before beginning work.
- 6.5.5 The Lead Authorized Employee cannot remove any locks or tags from the energy isolation devices unless all other Authorized Employees have first removed their locks and tags from the lockbox. If there is a need to remove a lock and tag from the lockbox because an Authorized Employee is not on site, the procedures listed in Section 7.0 of this program must be followed.

6.6 Energy Isolation Devices Not Capable of Accepting a Lock

- 6.6.1 If an energy isolation device is physically incapable of accepting a lock, a tagout system which will offer full employee protection similar to that of a lockout system shall be used.
- 6.6.2 The tagout system includes all the steps of this control of hazardous energy (lockout/tagout) program except the actual use of a lockout device on that particular energy isolation device. Additional means to be considered as a part of the demonstration of full employee protection shall include the implementation of additional safety measures such as the removal of an isolating circuit element, blocking of a controlling switch, opening of an extra disconnecting device, or the removal of a valve handle to reduce the likelihood of inadvertent energizing.

7.0 Removal of Authorized Employee Locks and Tags When Off-site

There may be times when the control of hazardous energy (lockout/tagout) task needs to be closed out to place a machine, equipment, or system back into service when an Authorized Employee, still on the lockout/tagout task, is off-site and cannot be located. Removal of an Authorized Employee lock and tag without the Authorized Employee's signature will require a review by the Authorized Employee's direct supervisor.

- 7.1 The Authorized Employee's supervisor will attempt to reach the Authorized Employee to determine if the control of hazardous energy (lockout/tagout) task may be closed. If the Authorized Employee indicates that the task may be closed, the Authorized Employee must return to the site to follow the normal lockout/tagout energy isolation device removal procedure.
- 7.2 If the Authorized Employee cannot be contacted or cannot return to the site, the Authorized Employee's supervisor may authorize removal of the Authorized Employee from the control of hazardous energy (lockout/tagout) task.
- 7.3 If the supervisor authorizes the removal of the Authorized Employee's lock(s) and tag(s) all potentially Affected Employees shall be notified.
- 7.4 The Authorized Employee will be contacted by their supervisor immediately upon their return to work, to notify them that they have been removed from the control of hazardous energy (lockout/tagout) task.

8.0 Contractors

Penn and the contractor must inform each other of their respective control of hazardous energy (lockout/tagout) procedures. The responsibility for training contractor employees lies with their

employer. Penn shall ensure that its employees understand and comply with the restrictions and prohibitions of the outside employer's control of hazardous energy program. Prior to the contractor performing work, a designated point of contact will be made within the contractor's organization for the purpose of interfacing and coordinating the control of hazardous energy (lockout/tagout) procedures.

9.0 Control of Hazardous Energy (Lockout/Tagout) Periodic Inspections

Penn shall perform a periodic review of its Control of Hazardous Energy (Lockout/Tagout) Program and procedures for ensuring that the requirements of 29 CFR 1910.147 - The Control of Hazardous Energy (Lockout/Tagout) are being met. A written report shall be made documenting inspection findings, results, and as appropriate any corrective actions taken for control of hazardous energy (lockout/tagout) program deficiencies.

- 9.1 Periodic inspections of Penn's Control of Hazardous Energy (Lockout/Tagout) Program and procedures shall be conducted at least annually.
- 9.2 Periodic inspections shall be scheduled and documented in writing (See Attachment D).
- 9.3 A person trained as an Authorized Employee must perform the periodic inspection. The representative may not review any control of hazardous energy (lockout/tagout) task that they currently have responsibility for. The representative must review the procedures being implemented by and under the control of other Authorized Employees. The inspection shall include a review of each Authorized Employee's responsibilities under the program and related procedures. Written documentation of findings shall be produced and completed documents will be retained by EHRS or the School/Center, per Section 11. Periodic inspection documents shall be maintained for at least three years.
- 9.4 An inspection of various control of hazardous energy (lockout/tagout) tasks that have been closed out will be inspected to verify that they have been properly completed and closed out. Written documentation of findings shall be produced and completed documents shall be retained by FRES, EHRS, or the School/Center.
- 9.5 Active control of hazardous energy (lockout/tagout) tasks will be visually verified to ensure that all locks and tags are in place. The required control of hazardous energy (lockout/tagout) documents shall be verified to have been prepared in accordance with Penn's Control of Hazardous Energy (Lockout/Tagout) Program. Written documentation of findings shall be produced and completed documents will be retained by FRES, EHRS, or the School/Center, per Section 11.
- 9.6 If during the inspection a discrepancy or procedural inadequacy is found, steps shall be taken immediately to determine the reason for, and the corrective action necessary to remedy the

discrepancy. Written documentation of findings shall be produced and completed documents will be retained by FRES, EHRS, or the School/Center, per Section 11.

- 9.7 Discrepancies or noncompliance with Penn's Control of Hazardous Energy (Lockout/Tagout) Program and procedures will be corrected as soon as possible but no later than 60 days from the date of identification. The appropriate individuals shall be retrained if a discrepancy or inadequacy is identified.

10.0 Personnel Control of Hazardous Energy (Lockout/Tagout) Training

Employees shall be trained so that they understand the purpose and function of the Control of Hazardous Energy (Lockout/Tagout) Program and procedures. Employees shall also be trained so that they understand the purpose, content and requirements of 29 CFR 1910.147, The Control of Hazardous Energy (Lockout/Tagout).

- 10.1 Authorized Employees shall receive training in the recognition of sources of hazardous energy, the types and magnitude of hazardous energy, and the means and methods of isolation and control.
- 10.2 Affected Employees shall be instructed on the purpose and use of the Penn's Control of Hazardous Energy (Lockout/Tagout) Program.
- 10.3 Employee retraining will be conducted when there are changes in job assignment; machines, equipment, or processes; or in Penn's Control of Hazardous Energy (Lockout/Tagout) Program and procedures. Retraining will also be conducted when a periodic inspection of the effectiveness of this procedure reveals inadequacies in employee knowledge or performance.
- 10.4 A record of all training and retraining shall be maintained. The training record shall include the name of the employee, level of training, name of the instructor and the date of the training. EHRS shall upload training records into Penn's learning management system.

11.0 Recordkeeping

- 11.1 EHRS shall maintain Control of Hazardous Energy (Lockout/Tagout) Program training records.
- 11.2 FRES-related periodic inspections shall be maintained by EHRS.
- 11.3 School or Center-related periodic inspections shall be maintained by the school or center and EHRS.

12.0 References

- 12.1 [29 CFR 1910.147, The Control of Hazardous Energy \(Lockout/Tagout\).](#)
- 12.2 [29 CFR 1910.333, Personal Protective Equipment.](#)
- 12.3 [29 CFR 1926.417, Lockout and Tagging Circuits.](#)

ATTACHMENT A – EQUIPMENT HAZARDOUS ENERGY CONTROL PROCEDURE

Procedure ID:	Developed By:	Reviewed By:	Revised By:

Task:		Equipment ID:		
Building:	Area:	Rev:	Date:	Origin Date:
# Isolation Points to be Locked & Tagged.	Task Description/Notes			

Photo 1	Photo 2	Photo 3

ALWAYS PERFORM NORMAL SHUT DOWN BEFORE LOCKING OUT DISCONNECTS

ID	Source	Device	Location	Method	Check
E-1	Electrical				
M-2	Mechanical				
W-1	Hydraulic				
C-1	Chemical				
P-1	Pneumatic				
K-1	Kinetic Energy				
T-1	Thermal				
G-1	Gravity				

OPENING A GUARD DOES NOT CONSTITUTE A LOCKOUT
Any machine modifications must be shown in procedure. Contact EHRS to update procedure.

Equipment Specific Lockout-Tagout Procedure

#	STEP	DESCRIPTION
1	Notify	Notify all Affected Employees that servicing or maintenance is required on a machine, system, or equipment and that it must be shut down and locked out to perform the servicing or maintenance.
2	Review Lockout Procedure	The Authorized Employee shall refer to Penn's lockout procedure to identify the type and magnitude of the energy that the machine, system, or equipment utilizes, shall understand the hazards of the energy, and shall know the methods to control the energy.
3	Perform Machine Stop	If the machine, system, or equipment is operating, shut it down by the normal stopping procedures (depress the stop button, open switch, close valve, etc.). Reference operating procedure for normal shutdown.
4	Isolate Energy	Follow graphical lockout-tagout procedure from top to bottom to deactivate the energy isolating device(s) so that the machine, system or equipment is isolated from the energy source(s). Note: It may be necessary to dissipate the non-lockable energy sources before isolating the lockable energy sources (i.e., lower machine to lowest position before locking out).
5	Lockout Energy	Perform all lockout-tagout procedure steps from top to bottom starting with page 1. Lockout & tagout of energy isolating device(s) with assigned individual lock(s) and tag(s).
6	Dissipate Energy	Stored or residual energy (such as that in capacitors, springs, elevated machine members, rotating flywheels, hydraulic systems, and air, gas, steam, or water pressure, etc.) must be dissipated or restrained by methods such as grounding, repositioning, blocking, bleeding down, etc.
7	Attempt Restart TRY STEP	Ensure that the equipment is disconnected from the energy source(s) by first checking that no personnel are exposed, then verify the isolation of the equipment by operating the push button or other normal operating control(s) or by testing to make certain the equipment will not operate. Caution: Return operating control(s) to neutral or "off" position after verifying the isolation of the equipment.

RESTORE TO SERVICE SEQUENCE		
#	STEP	DESCRIPTION
1	Check Machine, System, Equipment	Check the machine, system or equipment and the immediate area around it to ensure that nonessential items such as parts and tools have been removed and that the machine, system, or equipment components are operationally intact including replacement of guards, interlocks, etc.
2	Check Area	Check the work area to ensure that all employees have been safely positioned or removed from the area.
3	Verify	Verify that the controls are in neutral.
4	Remove Lockout	Remove the locks, tags and lockout devices and reenergize the machine, system, or equipment. Reverse the order of all lockout-tagout procedure steps from bottom to top starting from the last page. Note: The removal of some forms of blocking may require reenergization of the machine before safe removal.
5	Notify	Notify Affected Employees that the servicing or maintenance is completed, and the machine, system, or equipment is ready for use.

Scope: Utilize this procedure for all scheduled PM shutdowns, any maintenance task that requires you to place your body in harm's way of the equipment or if you must leave the area while the equipment is in service.

ATTACHMENT B – GROUP ROSTER

CONTROL OF HAZARDOUS ENERGY GROUP ROSTER		
Energy Control Procedure ID:	Building:	Task:
Lead Authorized Employee(s) <i>(print name)</i>	Lock Installed <i>(signature and date)</i>	Lock Removed <i>(signature and date)</i>
Authorized Employee(s) <i>(print name)</i>	Lock Installed <i>(signature and date)</i>	Lock Removed <i>(signature and date)</i>
Notes:		

ATTACHMENT C- PERIODIC REVIEW FORM

Periodic Review Form - Hazardous Energy Control (LOTO)

Required Frequency: Annually

To meet OSHA requirements, at least one person who performs the Hazardous Energy Control Assessment must be on the location's list of Authorized employees.

LOCKOUT/TAGOUT PERIODIC REVIEW FORM

This form shall be used to verify that a lockout/tagout procedure is correct and current. The review shall certify that the procedure is utilized properly and shall be performed at least annually.

Employee Name: _____ Date: _____

Trade/Shop _____

Equipment: _____ Location: _____

Check all energy sources that were locked and tagged out:

- 1. Electrical _____
- 2. Pneumatic _____
- 3. Hydraulic _____
- 4. Thermal _____
- 5. Mechanical _____
- 6. Chemical _____
- 7. Other _____

Were all energy sources de-energized according to the machine specific procedure?

_____ Yes _____ No

Are the written procedures adequate in controlling all energy sources?

_____ Yes _____ No

Were the results of this review covered with the employee(s)?

_____ Yes _____ No

List steps taken to correct deviations or deficiencies with this procedure:

Reviewing Employee: _____

FRES employees shall return completed forms to the **FRES Director of Safety for review.**

All other employees shall return completed forms to **EHRS.**

FRES/EHRS shall retain this form on file for one (1) year.