

Blockley Hall

Rev. April 2022

The following areas contain asbestos-containing textured ceiling paint:

3rd floor:

Suite 333 (includes rooms 309, 310 and 311)
Rooms 313, 314, 315, 316

The remainder of the 3rd floor was previously abated

10th floor:

No abatement has been done. Asbestos-containing textured ceiling paint can be found throughout the floor

Asbestos has been removed from all other floors 1-14.