

Weekly Eyewash Inspection Log

Location _____

Year: 2025

Instructions: Activate emergency eyewash to ensure proper operation.

- Sufficient water flows from eyewash, so that streams of water can reach both eyes.
- Water temperature is cold to warm. Hot, steaming water is unacceptable.
- Water runs clear after an initial flush period.
- If there are any issues with the above or issues with the physical state of the eyewash, talk to your building administrator.
- Keep weekly eyewash inspection log sheet for 3 years.

Schedule: EHRS requires weekly eyewash activation by the users of the space where the eyewash is located.

Week of	Date	Initials	Week of	Date	Initials	Week of	Date	Initials
12/29/2024			5/4/2025			9/7/2025		
1/5/2025			5/11/2025			9/14/2025		
1/12/2025			5/18/2025			9/21/2025		
1/19/2025			5/25/2025			9/28/2025		
1/26/2025			6/1/2025			10/5/2025		
2/2/2025			6/8/2025			10/12/2025		
2/9/2025			6/15/2025			10/19/2025		
2/16/2025			6/22/2025			10/26/2025		
2/23/2025			6/29/2025			11/2/2025		
3/2/2025			7/6/2025			11/9/2025		
3/9/2025			7/13/2025			11/16/2025		
3/16/2025			7/20/2025			11/23/2025		
3/23/2025			7/27/2025			11/30/2025		
3/30/2025			8/3/2025			12/7/2025		
4/6/2025			8/10/2025			12/14/2025		
4/13/2025			8/17/2025			12/21/2025		
4/20/2025			8/24/2025			12/28/2025		
4/27/2025			8/31/2025					